

FIRST SCHEDULE

GUIDELINES FOR MINIMUM QUALIFICATION AND EXPERIENCE REQUIRED FOR ACCEPTANCE OF INDEPENDENT QUALIFIED PERSONS STATUS

Note: Evidence of a working knowledge and/or experience **MUST** accompany each application and be completed in Part B of the Application Form.

			Insp	Mtc
A	Automated sprinkler systems or other systems for fire protection	<ul style="list-style-type: none"> Registered fire engineer, and /or evidence of 5 years experience as a Sprinkler Systems Technician. 	✓	✓
B	Automatic fire doors forming part of a fire wall	<ul style="list-style-type: none"> Evidence of suitable experience as an Installation Technician. 	✓	✓
C	Emergency warning system for fire or other dangers	<ul style="list-style-type: none"> Type 1 & 2 alarms inspection. Evidence of suitable experience in testing systems and evidence of a working knowledge of Clause F7 of NZBC and approved documents. 	✓	
		<ul style="list-style-type: none"> Type 1 & 2 alarms for maintenance. Evidence of suitable experience as a technician and evidence of a working knowledge of Clause F7 of NZBC and approved documents. 	✓	✓
		<ul style="list-style-type: none"> Type 3 & 4 alarms. Evidence of a working knowledge of Clause F7 of NZBC and approved documents, and 3 years experience as a technician. 	✓	✓
D	Emergency Lighting System	<ul style="list-style-type: none"> Registered electrician and evidence of a working knowledge of Clause F6 of NZBC and approved documents. 	✓	✓
		<ul style="list-style-type: none"> Evidence of testing system and working knowledge of Clause F6 of NZBC and approved documents. 	✓	
E	Escape route pressurisation unit	<ul style="list-style-type: none"> Registered Fire Engineer, and/or evidence of suitable qualification or experience as deemed necessary. 	✓	✓
F	Riser mains for fire service use	<ul style="list-style-type: none"> Evidence of 5 years experience as an installation technician, or other appropriate experience. 	✓	✓
G	Automatic backflow preventer connected to potable water supply	<ul style="list-style-type: none"> Registered craftsman plumber. Demonstration of a working knowledge as an installation technician; or 	✓	✓
		<ul style="list-style-type: none"> Suitable NZQA standard qualification. 	✓	
H	Lifts, escalators, travelators or similar system	<ul style="list-style-type: none"> Practising mechanical engineer, or evidence of 5 years experience as an installation technician. 	✓	✓
I	Mechanical ventilation or air conditioning	<ul style="list-style-type: none"> Registered mechanical engineer (heating and ventilating), or evidence of 5 years experience as installation technician. 	✓	✓
J	Any other mechanical, electrical or electronic system whose proper operation is necessary for compliance with the Building Code	<ul style="list-style-type: none"> Evidence of suitable qualification or 5 years experience as a technician in the appropriate field. 	✓	✓

Date of Issue: 19 September 2000

			Insp	Mtc
K	Building maintenance units	<ul style="list-style-type: none"> Registered structural or mechanical engineer or Evidence of suitable qualification and 5 years experience as installation technician. 	✓	✓
			✓	
L	Such signs as are required by the Building Code in respect of any of the above systems of features	<ul style="list-style-type: none"> Evidence of working knowledge of NZS 1900 Chapter 5. Appropriate clauses of NZBC, Building Act 1991. <p>Note: Signs relating to the above are only for systems approved.</p>	✓	✓
M	Means of escape from fire	<ul style="list-style-type: none"> Evidence of a thorough working knowledge of NZSS 1900 chapter 5, Clause D1 NZBC and approved documents. Clause C2 NZBC and approved documents. NZS 4121 plus evidence of suitable experience working with the above documents. High-Risk Buildings such as: <ul style="list-style-type: none"> Places of assembly (more than 100 persons) Hotels/Night Clubs/Taverns Stadiums High Rise Building (3 or more floors) Factories (10 or more persons) Apartments OPH Hospitals Theatres/Cinemas Terminal Buildings Supermarkets/Apartment Stores Any other buildings of similar risk Low Risk Buildings such as: <ul style="list-style-type: none"> Places of assembly (less than 100 people) Buildings less than 3 floors Factories less than 10 persons Any other building of similar risk A less qualification and experience may be considered for the Low Risk Buildings list above. 	✓	✓
			✓	✓
			✓	✓
			✓	✓
N	Safety Barriers	<ul style="list-style-type: none"> Evidence of knowledge of NZSS 1900 chapter 5, appropriate Clauses of NZBC, NZS 4121. <p>Note: (N) may not be approved without (M) Means of Escape.</p>	✓	✓
O	Access and facilities for people with disabilities	<ul style="list-style-type: none"> Evidence of knowledge of NZSS 1900 chapter 5, appropriate Clauses of NZBC, NZS 4121, NZ Building Act 1991, section 47A. <p>Note: (O) may not be approved without (M) Means of Escape, unless a Barrier Free Qualification has been obtained.</p>	✓	✓
P	Hand held hose reels for fire fighting	<ul style="list-style-type: none"> Evidence of knowledge of NZS 4503:1993. 	✓	✓
Q	Signs required by the Building Code or Section 25 of the Disabled Persons Community Welfare Act 1975	<ul style="list-style-type: none"> Evidence of knowledge of NZS 4121, appropriate Clauses of NZBC, NZS 1900 chapter 5, NZ Building Act 1991, section 47A. <p>Note: (Q) may not be approved with (M) Means of Escape, unless a Barrier Free Qualification has been obtained.</p>	✓	✓

Date of Issue: 19 September 2000