

Water Quality Report: Geraldine (GER001)

Period: 2026, Quarter 3 - From 01/07/2026 to 30/09/2026

Period Results for Geraldine (GER001) Components

Water Supply	Geraldine (GER001)	Results
Source Water	Geraldine Bore 1 (G00204)	
	Sampling for Chemical Compliance	Complies
	Monitoring for Cyanobacteria	N/A
Source Water	Geraldine Bore 2 (G11318)	
	Sampling for Chemical Compliance	Complies
	Monitoring for Cyanobacteria	N/A
Source Water	Geraldine Bore 3 (G11319)	
	Sampling for Chemical Compliance	Complies
	Monitoring for Cyanobacteria	N/A
Source Water	Geraldine Bore 4 (G11320)	
	Sampling for Chemical Compliance	Complies
	Monitoring for Cyanobacteria	N/A
Treatment Plant	Geraldine (TP00305)	
	Sampling for Chemical Compliance	Complies
	pH Range of Treated Water	Complies
Distribution	Geraldine (GER001GE)	
	Sampling for Chemical Compliance	Complies
	Sampling for Microbiological Compliance	Complies
	Residual Disinfection (Free Available Chlorine within Network)	Complies
Distribution	Geraldine Downs (TEM002GD)	
	Sampling for Chemical Compliance	Complies
	Sampling for Microbiological Compliance	Complies
	Residual Disinfection (Free Available Chlorine within Network)	Complies
Distribution	Geraldine Flat (TEM002GF)	
	Sampling for Chemical Compliance	Complies
	Sampling for Microbiological Compliance	Complies
	Residual Disinfection (Free Available Chlorine within Network)	Complies

Latest Source Water Composition Information

Source - Geraldine Bore 1 (G00204) Water Composition:

Lab #	Date	Chemical	Unit	Result	MAV %
4013982	21/10/2025	Langelier Saturation Index		-2.1	-
4013982	21/10/2025	Sample Temperature	°C	20.0	-
4131174	10/03/2026	Dissolved Calcium	g/m ³	8.9	-
4013982	21/10/2025	Turbidity	NTU	0.23	-
4112344	25/02/2026	pH	pH Units	7.1	-
4131174	10/03/2026	Total Alkalinity	g/m ³ as CaCO ₃	33	-
4013982	21/10/2025	Free Carbon Dioxide	g/m ³ at 25°C	6.0	-
4112344	25/02/2026	Total Hardness	g/m ³ as CaCO ₃	31	-
4112344	25/02/2026	Electrical Conductivity (EC)	mS/m	7.6	-
4013982	21/10/2025	Approx Total Dissolved Salts	g/m ³	42	-
4131174	10/03/2026	Total Arsenic	g/m ³	<0.0010	0%
4013982	21/10/2025	Total Boron	g/m ³	<0.053	0%
4013982	21/10/2025	Total Calcium	g/m ³	6.9	-
4131174	10/03/2026	Total Copper	g/m ³	0.0079	0.4%
4312241	09/09/2026	Total Iron	g/m ³	<0.02	-
4131174	10/03/2026	Total Lead	g/m ³	0.00035	3.5%
4013982	21/10/2025	Total Magnesium	g/m ³	1.47	-
4312241	09/09/2026	Total Manganese	g/m ³	<0.0005	0%
4013982	21/10/2025	Total Potassium	g/m ³	0.52	-
4013982	21/10/2025	Total Sodium	g/m ³	3.1	-
4112344	25/02/2026	Total Zinc	g/m ³	0.0015	-
4131174	10/03/2026	Chloride	g/m ³	1.4	-
4312241	09/09/2026	Nitrate-N	g/m ³	0.50	4.4%
4131174	10/03/2026	Sulphate	g/m ³	1.7	-

Note: This data shows only the Nitrate-N (NO₃-N) result, not Nitrate (NO₃).

Source - Geraldine Bore 2 (G11318) Water Composition:

Lab #	Date	Chemical	Unit	Result	MAV %
4112344	25/02/2026	Dissolved Calcium	g/m ³	8.8	-
4112344	25/02/2026	pH	pH Units	6.8	-
4112344	25/02/2026	Total Alkalinity	g/m ³ as CaCO ₃	32	-
4112344	25/02/2026	Total Hardness	g/m ³ as CaCO ₃	29	-
4112344	25/02/2026	Electrical Conductivity (EC)	mS/m	7.6	-
4112344	25/02/2026	Total Arsenic	g/m ³	<0.0011	0%
4112344	25/02/2026	Total Copper	g/m ³	<0.00053	0%
4112344	25/02/2026	Total Lead	g/m ³	<0.00011	0%
4112344	25/02/2026	Total Zinc	g/m ³	<0.0011	-
4112344	25/02/2026	Chloride	g/m ³	1.7	-
4112344	25/02/2026	Nitrate-N	g/m ³	0.44	3.9%
4112344	25/02/2026	Sulphate	g/m ³	1.9	-

Note: This data shows only the Nitrate-N (NO₃-N) result, not Nitrate (NO₃).

Source - Geraldine Bore 3 (G11319) Water Composition:

Lab #	Date	Chemical	Unit	Result	MAV %
4112344	25/02/2026	Dissolved Calcium	g/m ³	9.5	-
4112344	25/02/2026	pH	pH Units	7.0	-
4112344	25/02/2026	Total Alkalinity	g/m ³ as CaCO ₃	32	-
4112344	25/02/2026	Total Hardness	g/m ³ as CaCO ₃	32	-
4112344	25/02/2026	Electrical Conductivity (EC)	mS/m	7.5	-
4112344	25/02/2026	Total Arsenic	g/m ³	<0.0011	0%
4112344	25/02/2026	Total Copper	g/m ³	<0.00053	0%
4112344	25/02/2026	Total Lead	g/m ³	<0.00011	0%
4112344	25/02/2026	Total Zinc	g/m ³	<0.0011	-
4112344	25/02/2026	Chloride	g/m ³	1.6	-
4112344	25/02/2026	Nitrate-N	g/m ³	0.39	3.5%
4112344	25/02/2026	Sulphate	g/m ³	1.9	-

Note: This data shows only the Nitrate-N (NO₃-N) result, not Nitrate (NO₃).

Source - Geraldine Bore 4 (G11320) Water Composition:

Lab #	Date	Chemical	Unit	Result	MAV %
4112344	25/02/2026	Dissolved Calcium	g/m ³	9.4	-
4112344	25/02/2026	pH	pH Units	6.9	-
4112344	25/02/2026	Total Alkalinity	g/m ³ as CaCO ₃	32	-
4112344	25/02/2026	Total Hardness	g/m ³ as CaCO ₃	31	-
4112344	25/02/2026	Electrical Conductivity (EC)	mS/m	7.7	-
4112344	25/02/2026	Total Arsenic	g/m ³	<0.0011	0%
4112344	25/02/2026	Total Copper	g/m ³	<0.00053	0%
4112344	25/02/2026	Total Lead	g/m ³	<0.00011	0%
4112344	25/02/2026	Total Zinc	g/m ³	<0.0011	-
4112344	25/02/2026	Chloride	g/m ³	1.6	-
4112344	25/02/2026	Nitrate-N	g/m ³	0.46	4.1%
4112344	25/02/2026	Sulphate	g/m ³	1.9	-

Note: This data shows only the Nitrate-N (NO₃-N) result, not Nitrate (NO₃).