



Certificate of Analysis

Page 1 of 1

Client: Timaru District Council	Lab No: 2852800	SPV1
Contact: Pauline Robertson	Date Received: 03-Feb-2022	
C/- Timaru District Council	Date Reported: 11-Feb-2022	
PO Box 522	Quote No: 30978	
Timaru 7940	Order No:	
	Client Reference:	
	Submitted By: Pauline Robertson	

Sample Type: Aqueous

Sample Name:	Opihi Gallery-Well 01-Feb-2022 3:10 pm	Monitoring Well 6 01-Feb-2022 3:20 pm	26A King St 02-Feb-2022 1:00 pm	108 Meadows Rd 02-Feb-2022 12:40 pm	70 Morgans Rd 02-Feb-2022 3:30 pm
Lab Number:	2852800.1	2852800.2	2852800.3	2852800.4	2852800.5
Dissolved Manganese	g/m ³ 0.055 #1	2.3 #1	0.0024	0.0014	0.0068
Total Manganese	g/m ³ 0.054 #1	2.2 #1	0.46	0.0139	0.0119

Sample Name:	12 Mountain View Rd 02-Feb-2022 1:20 pm	300 Otipua Rd 02-Feb-2022 3:45 pm			
Lab Number:	2852800.6	2852800.7			
Bromate	g/m ³ < 0.005	< 0.005	-	-	-

Analyst's Comments

#1 It has been noted that the result for the dissolved fraction was greater than that for the total fraction, but within analytical variation of the methods.

Summary of Methods

The following table(s) gives a brief description of the methods used to conduct the analyses for this job. The detection limits given below are those attainable in a relatively simple matrix. Detection limits may be higher for individual samples should insufficient sample be available, or if the matrix requires that dilutions be performed during analysis. A detection limit range indicates the lowest and highest detection limits in the associated suite of analytes. A full listing of compounds and detection limits are available from the laboratory upon request. Unless otherwise indicated, analyses were performed at Hill Laboratories, 28 Duke Street, Frankton, Hamilton 3204.

Sample Type: Aqueous

Test	Method Description	Default Detection Limit	Sample No
Total Digestion	Nitric acid digestion. APHA 3030 E (modified) 23 rd ed. 2017.	-	1-5
Filtration for dissolved metals analysis	Sample filtration through 0.45µm membrane filter and preservation with nitric acid. APHA 3030 B 23 rd ed. 2017.	-	1-5
Dissolved Manganese	Filtered sample, ICP-MS, trace level. APHA 3125 B 23 rd ed. 2017.	0.0005 g/m ³	1-5
Total Manganese	Nitric acid digestion, ICP-MS, trace level. APHA 3125 B 23 rd ed. 2017 / US EPA 200.8.	0.00053 g/m ³	1-5
Bromate	Sample analysed as received, filtered if required. Ion Chromatography. US EPA Method 300.1 Part B (modified).	0.005 g/m ³	6-7

These samples were collected by yourselves (or your agent) and analysed as received at the laboratory.

Testing was completed between 09-Feb-2022 and 11-Feb-2022. For completion dates of individual analyses please contact the laboratory.

Samples are held at the laboratory after reporting for a length of time based on the stability of the samples and analytes being tested (considering any preservation used), and the storage space available. Once the storage period is completed, the samples are discarded unless otherwise agreed with the customer. Extended storage times may incur additional charges.

This certificate of analysis must not be reproduced, except in full, without the written consent of the signatory.

Ara Heron BSc (Tech)
Client Services Manager - Environmental



This Laboratory is accredited by International Accreditation New Zealand (IANZ), which represents New Zealand in the International Laboratory Accreditation Cooperation (ILAC). Through the ILAC Mutual Recognition Arrangement (ILAC-MRA) this accreditation is internationally recognised. The tests reported herein have been performed in accordance with the terms of accreditation, with the exception of tests marked * or any comments and interpretations, which are not accredited.