

SS 1 - AUTOMATIC SPRINKLER SYSTEMS

Address:			
Provided by (name):			
Equipment register			
No.	Make (major components)	Model	Location
1			
2			
3			
4			
Performance/Installation Standard:		<input type="checkbox"/> NZS 4541 Year _____ <input type="checkbox"/> NZS 4515 Year _____ <input type="checkbox"/> AS 1851 Year _____ <input type="checkbox"/> Specifically Designed Alternative Solution <input type="checkbox"/> Other (historical) _____	
Inspections & Maintenance Standard:		<input type="checkbox"/> NZS 4541 Year _____ <input type="checkbox"/> NZS 4515 Year _____ <input type="checkbox"/> AS 1851 Year _____ <input type="checkbox"/> Specifically designed solution provide details separately	
As a minimum these inspections and maintenance procedures will be carried out:		Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required.	
Equipment Requiring Weekly Maintenance: If ticked weekly inspections are required.		<input type="checkbox"/> Building contains Diesel Fire Pump <input type="checkbox"/> Building contains an Electric Fire pump without an alarm <input type="checkbox"/> Building contains a Direct Connection to the Fire Department that requires weekly maintenance	
Inspection frequency and responsibility:		<input type="checkbox"/> Weekly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		<input type="checkbox"/> Annually	<input type="checkbox"/> Owner <input type="checkbox"/> IQP
		Where the system is connected to the buildings emergency warning system, testing of the interface between the two systems should be carried out annually.	
As a minimum these reporting procedure will be carried out:		The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. • A Form 12A provided by an IQP annually 	